

**MURRAY / ARCHITECTS**

131 Ormond Center Court  
Destrehan, LA 70047  
(985) 764-7275 (ofc)  
(985) 725-0182 (fax)

**F A C S I M I L E**

TO:	ALL PLAN HOLDERS
COMPANY:	
FAX NUMBER:	

FROM:	MICHAEL TABB, AIA
REFERENCE:	HARRY HURST MIDDLE SCHOOL WING ADDITION
DESCRIPTION:	ADDENDUM NO. 5 ADDENDUM WITH FULL SIZE PLAN ATTACHED WILL BE DELIVERED, OR FEDERAL EXPRESSED

NUMBER OF PAGES: (Incl. Cover)	7
DATE SENT:	8/4/10

IF THERE ARE ANY PROBLEMS WITH THIS TRANSMISSION, OR YOU RECEIVED THIS  
TRANSMISSION IN ERROR, PLEASE CALL **985-764-7275**

Harry Hurst Middle School  
Wing Addition  
Addendum No. 5  
August 4, 2010

## ADDENDUM NO. 5

**PROJECT:** HARRY HURST MIDDLE SCHOOL  
NEW WING ADDITION  
170 ROADRUNNER LANE  
DESTREHAN, LA 70047

**Date of Addendum:** August 4, 2010

**Mandatory Pre-Bid Date:** July 20, 2010

**REVISED Bid Date:** August 10, 2010, 2:00 p.m.

### General

1. The gutter and downspouts shall be 24 gauge material to match finish roof.
2. Contractor to provide and install moisture vapor emission barrier in manufacturer's recommended thickness prior to installing resinous flooring.
3. All doors shall be 1-3/4" thick in lieu of 1-3/8" as shown on drawings.
4. Please refer to Section 15150 – Sanitary Waste and Vent Piping, 3.10 Piping Schedule for the sanitary piping schedule.

### Specifications


1. Section 04 2000 – Unit Masonry.
  - a. Contractor to install mortar net in sheets or strips full depth of cavity and install to full height of cavity.
  - b. Please change all references of "FBX" to "FBS" brick.
2. Section 06 4100 – Custom Casework, 2.1 Materials. Doors and drawers shall be frameless laminated with high pressure laminate from manufacturer's full line of wood grains. Color to be selected by Architect.
3. Section 09 5113 – Acoustical Panel Ceiling. Contractor to provide Armstrong Optima open plan acoustical ceiling tile, or approved equal. Contractor to provide sheetrock lay-in ceiling panel Clima Plus within all restrooms.
4. Section 09 6723 – Resinous Flooring and Base. Contractor shall pay for testing of floor slab per Section 3.2.C Testing of Floor Slab.

### Drawings

1. See attached Sketches SK-1, SK-2, SK-3 and SK-4.
2. Sheet A.7.4, Detail E-13. Please remove rebar from concrete stair treads.
3. Sheet C.1.3. Remove and replace with the attached sheet.
4. Sheet C.2.1. Add to the contract documents.
5. Contractor to provide and install eight (8) student lab tables and two (2) teacher lab tables as detailed in the attached Sketch SK-3.
6. Sheet A.2.2, Detail A-7. The downspout boot shall be 8"x8" cast iron boot by McKinley Iron Works. Boot shall be powder coated to match downspout color.

Harry Hurst Middle School  
Wing Addition  
Addendum No. 5  
August 4, 2010


7. Sheet S.0.1. In lieu of tip and butt requirements indicated in general note number 1 "Piles", refer to specification Section 31 6200 – Driven Piles. In addition, explanatory piles (and reaction piles) should be of adequate length to accommodate the load test.
8. All drawings on Sheet A.4.6 shall be  $\frac{1}{2}''=1'-0''$  scale in lieu of  $\frac{1}{8}''=1'-0''$  as shown on the sheet.



**MURRAY ARCHITECTS**  
 131 LOMOND CENTER SUITE  
 DUNELLEN, LA 70047  
 (985) 764-7275  
 FAX (985) 725-0182

Harry Hurst  
 New Wing Addition  
 sketch description  
 Boiler Room Section

project no.	date	drawing number
10078	8.4.2010	SK-1
file name	sheet/A.3.0.dwg	
issued for	Addendum #5	this drawing modifies A-16/A.3.8




8x8x16" CONCRETE BLOCK  
 MASONRY ANCHOR 24" O.C. VERTICAL  
 STEEL MEMBER  
 (SEE STRUCTURAL)  
 4x8x16" CONCRETE BLOCK

3/4" PLYWOOD MILLWORK  
 5/8" GYPSUM BOARD  
 2x4" METAL STUDS  
 2x4" BOTTOM TRACK

**MURRAY ARCHITECTS**  
 131 ORMOND CENTER COURT  
 DEERFIELD, IL 60015  
 (985) 725-0182  
 (985) 725-0182

**HARRY HURST MIDDLE SCHOOL WING ADDITION**  
 sketch description  
**MECHANICAL DUCT**

project number <b>1007</b>	date <b>8.4.2010</b>	drawing number <b>SK-2</b>
title name sheet/A.7.0.dwg.	issued for Addendum #5	this drawing modifies: N/A




project number 1007	date 8.4.2010	drawing number SK-3
file name sheet/A.7.0.dwg	issued for Addendum #5	this drawing modifies N/A

HARRY HURST MIDDLE SCHOOL WING ADDITION
sketch description LABORATORY TABLE SECTION

131 Ormond Center Court  
Indianapolis, IN 46047  
Phone (859) 794-7275  
Fax (859) 725-0392

**MURRAY ARCHITECTS**



project number 1007	date 8.4.2010	drawing number <b>SK-4</b>
file name sheet/A.1.0.dwg.	issued for Addendum #5	This drawing modifies: N/A

HARRY HURST MIDDLE SCHOOL WING ADDITION	Mechanical Yard
sketch description	

131 oxford center court  
 dallas, tx 75047  
 (985) 764-7275  
 fax (985) 725-0182

**MURRAY ARCHITECTS**