



- SPECIFIC NOTES:**
- ① PROVIDE GFCI RECEPTACLE IN PIT FOR SUMP PUMP. COORDINATE ROUGH-IN LOCATION WITH DIVISION 15 AND ELEVATOR DRAWINGS. (NEMA 3R RATING FOR RECEPTACLE).
 - ② PROVIDE GFCI RECEPTACLE, SWITCH AND FLUORESCENT LIGHT FIXTURE, LITHONIA #VR2C-32TRT-120. LOCATE IN ELEVATOR PIT AS DIRECTED BY THE ELEVATOR MANUFACTURER. (NEMA 3R RATING FOR SWITCH AND RECEPTACLE).
 - ③ INSTALL RECEPTACLE ABOVE MARKER BOARD AT APPROXIMATELY 7'-0" A.F.F. COORDINATE INSTALLATION WITH ARCHITECT PRIOR TO ROUGH-IN.
 - ④ INSTALL RECEPTACLE ON SIDE OF INSTRUCTORS TABLE. COORDINATE INSTALLATION WITH MILLWORK INSTALLER PRIOR TO ROUGH-IN.
 - ⑤ PROVIDE 120V. POWER CONNECTION TO FUME HOOD.
 - ⑥ CONNECT TO CIRCUIT LIC-16.
 - ⑦ PROVIDE WEATHERPROOF THERMAL SWITCH AND 120V POWER CONNECTION TO OUTDOOR CONDENSING UNIT. COORDINATE INSTALLATION LOCATION AND REQUIREMENTS WITH DIVISION 15 PRIOR TO ROUGH-IN.
 - ⑧ EXTEND POWER CIRCUITING FROM OUTDOOR UNIT TO INDOOR UNIT AC-1 IN ELEVATOR EQUIPMENT ROOM #217. SEE SHEET E2.01 FOR LOCATION.
 - ⑨ PROVIDE 120V POWER CONNECTION TO ELECTRIC HAND DRYER. COORDINATE LOCATION AND REQUIREMENTS WITH INSTALLER PRIOR TO ROUGH-IN.
 - ⑩ PROVIDE JUNCTION BOX AND 120V POWER CONNECTION FOR SUMP PUMP ALARM MODULE. COORDINATE INSTALLATION LOCATION AND REQUIREMENTS WITH DIVISION 15 PRIOR TO ROUGH-IN.

MURRAY ARCHITECTS
 1331 omnium center court
 Metairie, LA 70002
 (504) 885-7705
 fax (504) 725-0182

jba CONSULTING ENGINEERS
 JBA Consulting Engineers, Inc.
 JBA New Orleans
 3525 N Causeway Blvd
 Suite 500
 Metairie, LA 70002
 p 504.830.0139

no.	revisions	date
1		
2		
3		
4		
5		
6		

HARRY HURST MIDDLE SCHOOL WING ADDITION
 1 Roadrunner Lane, Destrehan, Louisiana 70047
 FIRST FLOOR POWER PLAN

drawing number
 project number 10.0123
 date 06.14.2010
 phase CD
E2.00

THESE DOCUMENTS ARE PROTECTED BY UNITED STATES COPYRIGHT LAW. THEY HAVE BEEN PREPARED SPECIFICALLY FOR THE CLIENT AND ARE NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE EXPRESS WRITTEN APPROVAL AND PARTICIPATION OF MURRAY ARCHITECTS. REPRODUCTION OF THESE DOCUMENTS MUST BE AUTHORIZED BY THE ARCHITECT. ALL RIGHTS ARE RESERVED TO MURRAY ARCHITECTS.

E2.00 FIRST FLOOR POWER PLAN

1/8" = 1'-0"