


- SPECIFIC NOTES:**
- ① PROVIDE 4SQ. x 3" DP JUNCTION BOX WITH BLANK COVERPLATE FLUSH IN WALL AT 18" A.F.F. INSTALL CONDUIT AS SHOWN BETWEEN CEILING PROJECTOR ROUGH-IN LOCATION AND JUNCTION BOX.
  - ② PROVIDE 48Q JUNCTION BOX IN JOIST SPACE FOR PROJECTOR CABLING TERMINATION. COORDINATE LOCATION WITH INSTALLER PRIOR TO ROUGH-IN.
  - ③ INSTALL DEVICE ABOVE MARKER BOARD AT APPROXIMATELY 7'-0" A.F.F. COORDINATE INSTALLATION WITH ARCHITECT PRIOR TO ROUGH-IN.
  - ④ INSTALL DEVICE ON SIDE OF INSTRUCTORS TABLE. COORDINATE INSTALLATION WITH MILLWORK INSTALLER PRIOR TO ROUGH-IN.
  - ⑤ PROVIDE 3'-0" LENGTH OF 2-1/2" CONDUIT WITH PLASTIC END BUSHINGS ABOVE CEILING FOR LOW VOLTAGE CABLING INSTALLATION.
  - ⑥ PROVIDE FOUR (4) 4" CONDUITS WITH PLASTIC END BUSHINGS STUBBED INTO ACCESSIBLE CEILING SPACE ON THIS FLOOR AND ROUTED DOWN INTO LT. ROOM #114 ON FIRST FLOOR.
  - ⑦ HEAT DETECTION LOCATED WITHIN 2' OF EACH SPRINKLER HEAD.
  - ⑧ ADDRESSABLE RELAY MODULES CONNECTED TO ELEVATOR CONTROLLER FOR ELEVATOR PRIMARY AND ALTERNATIVE RECALL AND THIRD CIRCUIT.
  - ⑨ ADDRESSABLE RELAY MODULE FOR ELEVATOR POWER SHUNT TRIP.



no.	revisions	date
1		
2		
3		
4		
5		
6		

**HARRY HURST MIDDLE SCHOOL WING ADDITION**  
 1 Roadrunner Lane, Destrehan, Louisiana 70047  
 SECOND FLOOR SPECIAL SYSTEMS PLAN

STATE OF LOUISIANA  
**ALVIN L. PHELPS, JR.**  
 LICENSE NO. 36202  
 PROFESSIONAL ELECTRICAL ENGINEER

MURRAY ARCHITECTS  
 project number 10.0123  
 date 06.14.2010  
 phase CD

**E3.01**

THESE DOCUMENTS ARE PROTECTED BY UNITED STATES COPYRIGHT LAW. THEY HAVE BEEN PREPARED SPECIFICALLY FOR THE CLIENT AND ARE NOT TO BE REPRODUCED, COPIED, OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, INCLUDING PHOTOCOPYING, RECORDING, OR BY ANY INFORMATION STORAGE AND RETRIEVAL SYSTEM, WITHOUT THE EXPRESS WRITTEN APPROVAL AND PARTICIPATION OF MURRAY ARCHITECTS. REPRODUCTION OF THESE DOCUMENTS WITHOUT THE EXPRESS WRITTEN APPROVAL OF MURRAY ARCHITECTS IS STRICTLY PROHIBITED. ALL RIGHTS ARE RESERVED TO MURRAY ARCHITECTS.

**E3.01 SECOND FLOOR SPECIAL SYSTEMS PLAN**

1/8" = 1'-0"

