



**SPECIFIC NOTES:**

- ① HEAT DETECTION LOCATED WITHIN 2' OF EACH SPRINKLER HEAD.
- ② LOCATE FIRE ALARM SMOKE DETECTOR AT THE TOP OF THE ELEVATOR SHAFT.
- ③ PROVIDE CONTROL RELAY AND MONITOR MODULE FOR ELEVATOR SHAFT FIRE SPRINKLER TAMPER SWITCH AND CONNECT TO FIRE ALARM SYSTEM.

COPYRIGHT © 2010 BY MURRAY ARCHITECTS, INC. ALL RIGHTS RESERVED. THIS DOCUMENT IS THE PROPERTY OF MURRAY ARCHITECTS, INC. AND IS NOT TO BE REPRODUCED OR TRANSMITTED IN ANY FORM OR BY ANY MEANS, ELECTRONIC OR MECHANICAL, WITHOUT THE EXPRESS WRITTEN PERMISSION OF MURRAY ARCHITECTS, INC. ALL RIGHTS ARE RESERVED TO MURRAY ARCHITECTS, INC.



**jba** JBA Consulting Engineers, Inc  
 JBA New Orleans  
 3525 N Causeway Blvd  
 Suite 500  
 Metairie, LA 70002  
 p.504.830.0139  
 consulting engineers

no.	revisions	date
1		
2		
3		
4		
5		
6		

**HARRY HURST MIDDLE SCHOOL  
 WING ADDITION**  
 1 Roadrunner Lane, Destrehan, Louisiana 70047  
 ATTIC SPECIAL SYSTEMS PLAN

ALVIN L. PHELPS, JR. License No. 12022 State of Louisiana IN ELECTRICAL ENGINEERING	MURRAY ARCHITECTS project number 10.0123 date 06.14.2010 phase CD	drawing number <b>E3.02</b>
---	--	--------------------------------

**E3.02 ATTIC SPECIAL SYSTEMS PLAN**

1/8" = 1'-0"

