

| SCHEDULE OF PANEL | | | | | | | | | | | |
|-----------------------|-------------------------|----------|------|------|--------|---|------|----------|------|-------|---------|
| NEMA 1 | | | | | | | | | | | |
| SYSTEM VOLTAGE | | | | | | | | | | | |
| 120/208 3ph, 4w/3e | | | | | | | | | | | |
| LOCATION: ELEC ROOM | | | | | | | | | | | |
| MOUNTING SURFACE | | | | | | | | | | | |
| 14000 | | | | | | | | | | | |
| SYM BREAKERS | | | | | | | | | | | |
| CIRCUIT | | | | | | | | | | | |
| CIR NO. | DESCRIPTION | CIB TRIP | POLE | KVA | PHASES | | | CIB TRIP | POLE | KVA | CIR NO. |
| | | | | | A | B | C | | | | |
| 1 | STORAGE GENERAL RECEIPT | 20 | 1 | 0.72 | 1.08 | | | 20 | 1 | 0.36 | 2 |
| 3 | STORAGE GENERAL RECEIPT | 20 | 1 | 0.72 | | | | 20 | 1 | 0.36 | 4 |
| 5 | SERGEANTS 218 RECEIPT | 20 | 1 | 0.54 | 1.26 | | | 20 | 1 | 0.36 | 6 |
| 7 | SERGEANTS 218 RECEIPT | 20 | 1 | 0.54 | | | | 20 | 1 | 0.36 | 8 |
| 9 | SERGEANTS 218 RECEIPT | 20 | 1 | 0.36 | 0.66 | | | 20 | 1 | 0.36 | 10 |
| 11 | ROOM 228 WORKSTATION | 20 | 1 | 0.30 | | | 1.02 | 20 | 1 | 0.36 | 12 |
| 13 | ROOM 228 WORKSTATION | 20 | 1 | 0.30 | 0.66 | | | 20 | 1 | 0.36 | 14 |
| 15 | GENERAL MECH RM RECEIPT | 20 | 1 | 0.54 | | | | 20 | 1 | 0.36 | 16 |
| 17 | GENERAL MECH RM RECEIPT | 20 | 1 | 0.36 | 0.18 | | | 20 | 1 | 0.36 | 18 |
| 19 | GEN PUMP RECEIPT | 20 | 1 | 0.18 | | | | 20 | 1 | 0.36 | 20 |
| 21 | EF-10 | 20 | 3 | 1.26 | 0.42 | | | 20 | 2 | 0.60 | 22 |
| 23 | EF-10 | 20 | 3 | 3.83 | | | | 20 | 2 | 0.60 | 24 |
| 27 | GATE OPERATOR | 20 | 3 | 1.26 | 1.28 | | | 20 | 2 | 0.60 | 28 |
| 29 | SF-11 | 20 | 3 | 1.26 | 0.42 | | | 20 | 2 | 0.60 | 30 |
| 31 | SF-11 | 20 | 3 | 1.26 | 0.42 | | | 20 | 2 | 0.60 | 32 |
| 33 | SPARE | 20 | 1 | | 1.50 | | | 20 | 2 | 0.60 | 34 |
| 35 | SPARE | 20 | 1 | | 1.50 | | | 20 | 2 | 0.60 | 36 |
| 37 | SPARE | 20 | 1 | | 1.50 | | | 20 | 2 | 0.60 | 38 |
| 39 | SPARE | 20 | 1 | | 1.50 | | | 20 | 2 | 0.60 | 40 |
| 41 | SPARE | 20 | 1 | | 1.50 | | | 20 | 2 | 0.60 | 42 |
| TOTAL KVA CONNECTED : | | | | | | | | | | 5.90 | 42 |
| TOTAL KVA CONNECTED : | | | | | | | | | | 17.87 | 42 |

| SCHEDULE OF PANEL | | | | | | | | | | | |
|-----------------------|------------------------------|----------|------|------|--------|---|------|----------|------|-------|---------|
| NEMA 1 | | | | | | | | | | | |
| SYSTEM VOLTAGE | | | | | | | | | | | |
| 120/208 3ph, 4w/3e | | | | | | | | | | | |
| LOCATION: ELEC ROOM | | | | | | | | | | | |
| MOUNTING SURFACE | | | | | | | | | | | |
| 14000 | | | | | | | | | | | |
| SYM BREAKERS | | | | | | | | | | | |
| CIR NO. | DESCRIPTION | CIB TRIP | POLE | KVA | PHASES | | | CIB TRIP | POLE | KVA | CIR NO. |
| | | | | | A | B | C | | | | |
| 1 | 1ST FLOOR LIGHTS | 20 | 1 | 1.67 | 1.43 | | | 20 | 1 | 0.36 | 2 |
| 3 | 1ST FLOOR LIGHTS | 20 | 1 | 0.78 | 1.50 | | | 20 | 1 | 0.72 | 4 |
| 5 | 2ND FLOOR LIGHTS | 20 | 1 | 0.66 | 1.32 | | 1.20 | 20 | 1 | 0.54 | 6 |
| 7 | 2ND FLOOR LIGHTS | 20 | 1 | 0.78 | | | | 20 | 1 | 0.54 | 8 |
| 9 | 2ND FLOOR LIGHTS | 20 | 1 | 1.37 | 1.30 | | 2.27 | 20 | 1 | 0.90 | 10 |
| 11 | 1ST FLOOR LIGHTS | 20 | 1 | 0.56 | 1.28 | | | 20 | 1 | 0.72 | 12 |
| 13 | CORRIDOR LOBBY LIGHTS | 20 | 1 | 1.31 | | | 0.94 | 20 | 1 | 0.90 | 14 |
| 15 | SITE LIGHTS | 20 | 1 | 0.40 | 1.04 | | | 20 | 1 | 0.54 | 16 |
| 17 | OFFICE RECEIPT | 20 | 1 | 0.18 | 0.72 | | | 20 | 1 | 0.54 | 18 |
| 19 | OFFICE RECEIPT | 20 | 1 | 0.72 | | | 1.08 | 20 | 1 | 0.36 | 20 |
| 21 | 4N6 | 20 | 1 | 1.98 | 1.05 | | | 20 | 1 | 0.36 | 22 |
| 23 | EF-10 | 20 | 3 | 1.26 | | | | 20 | 1 | 0.36 | 24 |
| 25 | EF-10 | 20 | 3 | 1.26 | 1.57 | | | 20 | 1 | 0.36 | 26 |
| 27 | 1ST & 2ND FLOOR LOBBY LIGHTS | 20 | 1 | 0.65 | 2.10 | | 1.37 | 20 | 1 | 0.60 | 28 |
| 29 | HTR-1 | 20 | 1 | 1.50 | 0.87 | | | 20 | 1 | 0.60 | 30 |
| 31 | EF-10 | 20 | 3 | 1.26 | | | | 20 | 1 | 0.36 | 32 |
| 33 | EF-10 | 20 | 3 | 1.26 | 1.56 | | | 20 | 1 | 0.36 | 34 |
| 35 | SEWER TREATMENT STATION | 20 | 1 | 1.86 | 1.03 | | | 20 | 1 | 0.48 | 36 |
| 37 | SEWER TREATMENT STATION | 20 | 1 | 1.86 | | | | 20 | 1 | 0.48 | 38 |
| 39 | SEWER TREATMENT STATION | 20 | 1 | 1.86 | | | | 20 | 1 | 0.48 | 40 |
| 41 | SEWER TREATMENT STATION | 20 | 1 | 1.86 | | | | 20 | 1 | 0.48 | 42 |
| TOTAL KVA CONNECTED : | | | | | | | | | | 8.38 | 42 |
| TOTAL KVA CONNECTED : | | | | | | | | | | 27.87 | 42 |

| SCHEDULE OF PANEL | | | | | | | | | | | |
|-----------------------|-------------|----------|------|-----|--------|---|---|----------|------|-------|---------|
| NEMA 1 | | | | | | | | | | | |
| SYSTEM VOLTAGE | | | | | | | | | | | |
| 120/208 3ph, 4w/3e | | | | | | | | | | | |
| LOCATION: ELEC ROOM | | | | | | | | | | | |
| MOUNTING SURFACE | | | | | | | | | | | |
| 14000 | | | | | | | | | | | |
| SYM BREAKERS | | | | | | | | | | | |
| CIR NO. | DESCRIPTION | CIB TRIP | POLE | KVA | PHASES | | | CIB TRIP | POLE | KVA | CIR NO. |
| | | | | | A | B | C | | | | |
| 1 | SPARE | 20 | 1 | | | | | 20 | 1 | | 2 |
| 3 | SPARE | 20 | 1 | | | | | 20 | 1 | | 4 |
| 5 | SPARE | 20 | 1 | | | | | 20 | 1 | | 6 |
| 7 | SPARE | 20 | 1 | | | | | 20 | 1 | | 8 |
| 9 | SPARE | 20 | 1 | | | | | 20 | 1 | | 10 |
| 11 | SPARE | 20 | 1 | | | | | 20 | 1 | | 12 |
| 13 | SPARE | 20 | 1 | | | | | 20 | 1 | | 14 |
| 15 | SPARE | 20 | 1 | | | | | 20 | 1 | | 16 |
| 17 | SPARE | 20 | 1 | | | | | 20 | 1 | | 18 |
| 19 | SPARE | 20 | 1 | | | | | 20 | 1 | | 20 |
| 21 | SPARE | 20 | 1 | | | | | 20 | 1 | | 22 |
| 23 | SPARE | 20 | 1 | | | | | 20 | 1 | | 24 |
| 25 | SPARE | 20 | 1 | | | | | 20 | 1 | | 26 |
| 27 | SPARE | 20 | 1 | | | | | 20 | 1 | | 28 |
| 29 | SPARE | 20 | 1 | | | | | 20 | 1 | | 30 |
| 31 | SPARE | 20 | 1 | | | | | 20 | 1 | | 32 |
| 33 | SPARE | 20 | 1 | | | | | 20 | 1 | | 34 |
| 35 | SPARE | 20 | 1 | | | | | 20 | 1 | | 36 |
| 37 | SPARE | 20 | 1 | | | | | 20 | 1 | | 38 |
| 39 | SPARE | 20 | 1 | | | | | 20 | 1 | | 40 |
| 41 | SPARE | 20 | 1 | | | | | 20 | 1 | | 42 |
| TOTAL KVA CONNECTED : | | | | | | | | | | 0.00 | 42 |
| TOTAL KVA CONNECTED : | | | | | | | | | | 27.87 | 42 |

HUSEMAN & Associates
 MECHANICAL ELECTRICAL PLUMBING FIRE PROTECTION
 Job No. 090003
 Drawn By: JC
 Checked By: JC
 3925 N. I-10 SERVICE RD
 METairie, LA 70002
 (504) 456-3119
 FAX (504) 456-3122

REGIONAL DESIGN GROUP, LLC
 300 LAFAYETTE STREET, SUITE 200
 NEW ORLEANS, LOUISIANA 70130
 (504) 523-6472 FAX (504) 529-1181

| revisions | |
|-----------|------|
| no. | date |
| 1 | |
| 2 | |
| 3 | |
| 4 | |
| 5 | |

JEFFERSON PARISH SHERIFF'S OFFICE
 4TH DISTRICT SUBSTATION
 JEFFERSON PARISH, LOUISIANA

PANEL SCHEDULES

| | |
|----------------|------------|
| File name | 090003E502 |
| Project number | 51172.03 |
| Date | 02-04-10 |
| Phase | CD |

E502