

VAV		BOX			SCHEDULE	
MARK	KW	VOLTS	PH	AMPS	FUSE	Panel Designation
2-1	4	277	1	14.4	20	H2-7
2-2	3	277	1	10.8	30	H2-8
2-3	5	277	1	18.1	30	H2-2
2-4	4	277	1	14.4	20	H2-4
2-5	4	277	1	14.4	20	H2-8
2-6	3	277	1	17.8	30	H2-10
2-8	6	277	1	21.2	30	H2-12
2-9	3	277	1	10.8	20	H2-11
2-10	3	277	1	10.8	20	H2-13
2-11	2	277	1	7.2	20	H2-15
2-12	2	277	1	7.2	20	H2-17
2-13	4	277	1	14.4	20	H2-19
2-14	11	480	3	13.2	20	H2-14, 16, 18
Conduit/Wiring	Disconnected Size					
1/2" C, 2#12AWG, 1#12GRD	30A, 277V, 2P, NEMA 1 FDS, FUSE 20A					
1/2" C, 2#12AWG, 1#12GRD	1/2" C, 2#12AWG, 1#12GRD					
3/4" C, 2#10AWG, 1#10GRD	30A, 277V, 2P, NEMA 1 FDS, FUSE 30A					
1/2" C, 2#12AWG, 1#12GRD	30A, 277V, 2P, NEMA 1 FDS, FUSE 30A					
1/2" C, 2#12AWG, 1#12GRD	30A, 277V, 2P, NEMA 1 FDS, FUSE 20A					
1/2" C, 2#12AWG, 1#12GRD	30A, 277V, 2P, NEMA 1 FDS, FUSE 20A					
1/2" C, 2#12AWG, 1#12GRD	30A, 277V, 2P, NEMA 1 FDS, FUSE 20A					
3/4" C, 2#10AWG, 1#10GRD	30A, 277V, 2P, NEMA 1 FDS, FUSE 30A					
1/2" C, 2#12AWG, 1#12GRD	30A, 277V, 2P, NEMA 1 FDS, FUSE 20A					
1/2" C, 2#12AWG, 1#12GRD	30A, 277V, 2P, NEMA 1 FDS, FUSE 20A					
1/2" C, 2#12AWG, 1#12GRD	30A, 277V, 2P, NEMA 1 FDS, FUSE 20A					
1/2" C, 2#12AWG, 1#12GRD	30A, 277V, 2P, NEMA 1 FDS, FUSE 20A					
1/2" C, 2#12AWG, 1#12GRD	30A, 480V, 3P, NEMA 1 FDS, FUSE 20A					

