



GENERAL NOTES - THIS SHEET.

- A. DUCT SIZES SHOWN ARE FREE AREA SIZES, SEE SPECIFICATIONS FOR DUCT MATERIALS AND INSULATION REQUIRED. INSULATE DIFFUSER BACK FANS.
- B. COORDINATE EXACT ROUTING OF ALL DUCTWORK SO AS NOT TO ALL CEILING GRILLES WITH GRID, LIGHTS, ETC.
- C. CONTRACTOR IS CAUTIONED NOT TO FABRICATE OR INSTALL ANY DUCTWORK UNTIL DUCTWORK SHOP DRAWINGS HAVE BEEN SUBMITTED AND APPROVED BY ARCHITECT. REPRODUCTION OF CONTRACT DOCUMENTS NOT ACCEPTABLE.
- D. SEE SHEET M403 FOR DUCT CONNECTION DETAILS.
- E. FLEX DUCT RUN OUTS TO SUPPLY AIR CEILING DIFFUSERS SHALL MATCH DIFFUSER NECK SIZES. MAXIMUM FLEX DUCT RUN OUTS SHALL BE LIMITED TO 8'-0". SUBSTITUTE RIGID METAL ROUND DUCTWORK IN LIEU THEREOF.
- F. FLEXIBLE DUCT CONNECTIONS SHALL BE MECHANICALLY FASTENED AND SEALED TO PREVENT LEAKAGE.
- G. PROVIDE MANUAL VOLUME DAMPER AT ALL UNIT OUTSIDE AIR INTAKES.
- H. DUCT MASTIC SHALL BE USED TO SEAL ALL TRANSVERSE SEAMS ON METAL DUCTS. PRESSURE SENSITIVE DUCT TAPE CANNOT BE USED TO SEAL TRANSVERSE SEAMS ON METAL DUCTS.
- I. PROVIDE FIRE DAMPER IN ALL RATED PARTITIONING WHERE DUCTWORK PENETRATES.
- J. ALL FIRE DAMPERS SHALL BE ACCESSIBLE THROUGH ACCESS PANELS. SEE SPECIFICATIONS FOR DETAILS.

SPECIFIC NOTES THIS SHEET.

- ① SEE SITE PLAN FOR CONTINUATION.
- ② 4" CHILLED WATER SUPPLY AND RETURN PIPING UP THROUGH MECHANICAL CHASE.
- ③ PROVIDE/INSTALL 12"X12" FILTER RACK FOR OUTSIDE AIR DUCT.
- ④ RUN 4" CW5 AND CAR LINE DOWN TO UNDERGROUND.

LUCIEN T. VIVIEN JR. AND ASSOCIATES, INC.
CONSULTING ENGINEERS
 1321 HICKORY AVENUE - SUITE 100
 HARAHAN, LOUISIANA 70123
 T (504) 218-5409 F (504) 218-5412
 www.vivienengineers.com

PROJECT DESIGN GROUP, LLC
 300 LAFAYETTE STREET, SUITE 200
 NEW ORLEANS, LOUISIANA 70130
 (504) 523-6472 FAX (504) 529-1181

REK ARCHITECTS, LLC
 21489 KOOP DRIVE, SUITE 5
 MANDEVILLE, LOUISIANA 70471
 (985) 875-7534 FAX (985) 875-7837

revisions		
no.	revision	date
1	ADDENDUM #2	11-13-09
2		
3		
4		
5		

SLIDELL MUNICIPAL CENTER BUILDING 2
 SLIDELL, LA

FIRST FLOOR PLAN - HVAC

file name	M201.dwg	drawing number	M201
project number	51093.02		
date	9-05-09		
phase	100% FIRE MARSHAL		

1 FIRST FLOOR PLAN - HVAC
 1/8"=1'-0"
 NORTH

STATE OF LOUISIANA
 Professional Engineer
 License No. 7985
 Lucien Eugene Vivien
 SEPTEMBER 5, 2009

THE INFORMATION CONTAINED IN THIS DOCUMENT IS PROPRIETARY TO LUCIEN T. VIVIEN, JR. AND ASSOCIATES, INC. IT IS TO BE USED ONLY FOR THE PROJECT AND SITE SPECIFICALLY IDENTIFIED HEREIN. ANY REPRODUCTION OR TRANSMISSION OF THIS DOCUMENT IN WHOLE OR IN PART WITHOUT THE WRITTEN CONSENT OF LUCIEN T. VIVIEN, JR. AND ASSOCIATES, INC. IS PROHIBITED.