

PANEL SCHEDULE--EXIST WITH NEW CIRCUITS,SEE PLAN					
PANEL "1A"		SECTION ONE		208Y/120V, 3Ø, 4WIRE A.I.C. 25K	
CKT.	DESCRIPTION	CKT. BKR TRIP POLES	CKT. BKR TRIP POLES	DESCRIPTION	CKT.
1	LIGHTING C.R.#1	20	1	LIGHTING C.R.#5	2
3	LIGHTING C.R.#2	20	1	LIGHTING C.R.#6	4
5	LIGHTING C.R.#3	20	1	LIGHTING C.R.#7	6
7	LIGHTING C.R.#4	20	1	LIGHTING CORR	8
9	LIGHTING OFFICE	20	1	LIGHTING OFFICE	10
11	LIGHTING OUTSIDE	20	1	RECEPT CR #1	12
13	LIGHTING OFFICE	20	1	RECEPT C.R.2	14
15	LIGHTING CORRIDOR	20	1	RECEPT. TEACHER LOUNGE	16
17	RECEPT OFFICE	20	1	RECEPT CR #3	18
19	RECEPT OFFICE	20	1	RECEPT. CR-4	20
21	RECEPT WAITING			RECEPT. C.R.#5	22
23	RECEPT WAIT			RECEPT. CR #6	24
25	RECEPT MEETING			RECEPT. CR#7	26
27	RECEPT CORR			RECEPT. FIRE ALAM PANEL	28
29	RECEPT CHILLER			RECEPT. CHILLER EQUIP. PAD	30
31	RECEPT ELEV. PIT	20		RECEPT. GFI/WP ELEV.CONT	32
33	INTERCOM PANEL	20	1	RECEPT. ELEV. CONT	34
35	LIGHTING STAIR	20	1	RECEPT. WAITING	36
37	LIGHTING TEACHER LAUNGE	20	1	SPARE	38
39	SPARE	20	1	SPARE	40
41	SPARE	20	1	SPARE	42

PANEL SCHEDULE--EXIST					
PANEL "2L"		SECTION ONE		208Y/120V, 3Ø, 4WIRE A.I.C. 25K	
CKT.	DESCRIPTION	CKT. BKR TRIP POLES	CKT. BKR TRIP POLES	DESCRIPTION	CKT.
1	LIGHTING C.R.#12	20	1	LIGHTING C.R.#9	2
3	LIGHTING C.R.#13	20	1	LIGHTING C.R.#10	4
5	LIGHTING C.R.#14	20	1	LIGHTING C.R.#11	6
7	LIGHTING C.R.#15	20	1	LIGHTING OUTSIDE	8
9	LIGHTING C.R.#16	20	1	REFRIGERATOR	10
11	LIGHTING C.R.#8	20	1	RECEPT. LOUNGE	12
13	HAND DRYER BATHROOM	25	1	HAND DRYER BATHROOM	14
15	LIGHTING CORRIDOR	20	1	HAND DRYER BATHROOM	16
17	HAND DRYER BATHROOM	25	1	SPARE	18
19	RECEPT RM.#12	20	1	RECEPT. COOR/BATH.	20
21	RECEPT RM.#13	20	1	RECEPT. C.R.10	22
23	RECEPT RM.#14	20	1	RECEPT. C.R.10	24
25	RECEPT RM.#15	20	1	RECEPT. TEACH. LOUNGE	26
27	RECEPT RM.#16	20	1	RECEPT. TEACH. LOUNGE	28
29	SPARE	20	1	RECEPT. C.R.#7	30
31	SPARE	20	1	RECEPT. C.R.#7&5	32
33	RECEPT ELECT.RM.	20	1	RECEPT. C.R.#3&1	34
35	FIRE ALARM PANEL	20	1	RECEPT. C.R.1	36
37	RECEPT P.A. SYSTEM	20	1	SPARE	38
39	SPARE	20	1	SPARE	40
41	SPARE	20	1	SPARE	42

PANEL SCHEDULE--EXIST					
PANEL "1A"		SECTION TWO		208Y/120V, 3Ø, 4 WIRE A.I.C. 25K	
CKT.	DESCRIPTION	CKT. BKR TRIP POLES	CKT. BKR TRIP POLES	DESCRIPTION	CKT.
43	LIGHTING PARKING	20	2	CANOPY LIGHT	44
45					46
47	SIGN	20	2	LIGHT POLE LIGHT	48
49					50
51	POLE RECEPT.	20	1	RECEPT. GFI TEACHER LOUNGE	52
53	RECEPT. OUTSIDE GFI	20	1	RECEPT. REFRIGERATOR TEACHER LOUNGE	54
55	RECEPT. TEL. BOARD	20	1	ELECT. WATER HEATER (INLINE)	56
57	SPARE	20	1	SPARE	58
59	SPARE	20	1	SPARE	60
61	SPARE	20	1	SPACE	62
63	SPACE	-	-	SPACE	64
65					66
67					68
69					70
71					72
73					74
75					76
77					78
79					80
81					82
83					84

PANEL SCHEDULE--EXIST					
PANEL "AC"		SECTION 1		208Y/120V, 3Ø, 4 WIRE A.I.C. 65K	
CKT.	DESCRIPTION	CKT. BKR TRIP POLES	CKT. BKR TRIP POLES	DESCRIPTION	CKT.
1	AHU-1	45	3	AHU-4	2
3					4
5					6
7	AHU-2	45	3	AHU-5	8
9					10
11					12
13	AHU-6	45	3	AHU-12	14
15					16
17					18
19	AHU-17	45	3	AHU-18	20
21					22
23					24
25	AHU-2	45	3	AHU-8	26
27					28
29					30
31	AHU-13	45	3	LIGHTING	32
33				RECEPT.	34
35				RECEPT.	36
37	RECEPT	20	1	J.BOX FOR ELEV. CTL.	38
39	RECEPT	20	1	RECEPT. ELEV. EQUIP.	40
41	RECEPT	20	1	SPACE	42

PANEL SCHEDULE--EXIST					
PANEL "HB"		SECTION TWO		208Y/120V, 3Ø, 4 WIRE A.I.C. 65K	
CKT.	DESCRIPTION	CKT. BKR TRIP POLES	CKT. BKR TRIP POLES	DESCRIPTION	CKT.
1	CHILLER	400	3	PANEL "AC"	2
3					4
5					6
7	CHILLED WATER PUMP-1	400	3	PANEL "LA"	8
9					10
11					12
13	CHILLED WATER PUMP-2	400	3	PANEL "2L"	14
15					16
17					18
19	SPACE			SPACE	20
21	SPACE			SPACE	22
23					24
25					26
27					28
29					30
31					32
33					34
35					36
37					38
39					40
41					42

PANEL SCHEDULE--EXIST					
PANEL "AC"		SECTION TWO		208Y/120V, 3Ø, 4 WIRE A.I.C. 65K	
CKT.	DESCRIPTION	CKT. BKR TRIP POLES	CKT. BKR TRIP POLES	DESCRIPTION	CKT.
43	AHU-3	45	3	AHU-9	44
45					46
47					48
49	AHU-19	45	3	AHU-14	50
51					52
53					54
55	AHU-4	45	3	AHU-20	56
57					58
59					60
61	AHU-10	45	3	AHU-5	62
63					64
65					66
67	AHU-21	45	3	AHU-15	68
69					70
71					72
73	ELEVATOR	125	3	FCU-3	74
75				SPACE	76
77				SPACE	78
79	EUH (MEZZ. FLOOR)	35	3	EUH (MEZZ. FLOOR)	80
81					82
83					84



M-K ENGINEERING, INC.
 CONSULTING ENGINEERS
 HVAC-PLUMBING-FIRE PROTECTION-ELECTRICAL
 4323 Division Street, Suite 211
 Metairie, LA 70002
 Tel:(504) 887-2376, Fax:(504) 887-2302
 Email: MKansagra@M-K-E.com
 M-K Project No.: 02105

John E. Campo, Architect
 105 Ducaquet Dr.
 Destrehan, LA 70047
 (985) 764-8859

Campo Design
 ARCHITECTS

THE MSGR. JOHN H. PHUC
 EDUCATION CENTER - PHASE III
 13396 RIVER ROAD, DESTREHAN, LOUISIANA
 ST. CHARLES BORROMEO CATHOLIC CHURCH PARISH

E108
 8 OF 8 SHEETS
 DATE:
 SEPT. 11, 2009
 CD - 1705