



ELECTRICAL
SECOND FLOOR PLAN - DEMOLITION

SCALE: 1/8"=1'-0"

- NOTES:**
- ELECTRICAL EQUIPMENT SHOWN DASHED IS EXISTING.
 - EXISTING AHU'S ON 2ND FLOOR, AIR-COOLED CHILLERS ON ROOF, GAS FIRED WATER HEATER, CONDENSING UNITS ON ROOF, PUMP MOTORS, & GA FAN MOTOR WILL REMAIN AS INDICATED UNDER DIV. 15 OF THE WORK. SEE DIVISION 15 DRAWINGS.
 - REMOVE EXISTING VANDALIZED MAGNETIC STARTERS, SAFETY SWITCHES, SMOKE/HEAT DETECTORS, DUCT DETECTORS, ASSOCIATED WITH EXISTING MECHANICAL EQUIPMENT (AHU'S, PUMPS, GA FAN, BOILER, GAS FIRED WATER HEATER, AIR COOLED CHILLERS ON ROOF, CONDENSING UNITS ON ROOF, ETC.) TO BE REUSED.
 - UNLESS OTHERWISE NOTED, DASHED ELECTRICAL EQUIPMENT SHALL BE REMOVED AS WELL AS ASSOCIATED WIRING, EXPOSED RACEWAYS, ETC. PATCH, PAINT, WEATHERPROOF, ETC. EXISTING WALLS TO SUIT.
 - EXISTING LIGHTNING PROTECTION SYSTEM SHALL REMAIN AS DIRECTED BY ARCHITECT/OWNER AND SHALL BE "RECONDITIONED" AS WORK OF A FUTURE PROJECT.
 - WHERE EXISTING LIGHTING, SWITCHES, AND RECEPTACLES, AND ASSOCIATED WIRING, RACEWAY SYSTEMS, ETC. ARE TO BE REUSED WHERE NOT DAMAGED BY FLOOD WATERS AND/OR VANDALISM, PROVIDE NEW WIRING, RACEWAY SYSTEMS, CONNECTIONS, ETC. TO SUIT TO EXTEND EXISTING WIRING IN RACEWAY SYSTEMS AND MAKE NECESSARY CONNECTIONS TO NEW WIRING DEVICES AND TO NEW SOURCES OF POWER TO RE-ENERGIZE THE EXISTING CIRCUITS (AFTER RECERTIFICATION OF EXISTING WIRING).
 - PROVIDE BLANK PLATES, ETC. ON EXISTING FLUSH MOUNTED BOXES WHICH ARE TO REMAIN AND ARE NOT REUSED FOR NEW WIRING DEVICES. FINISH OF PLATES SHALL MATCH FINISH OF NEW PLATES.
 - SEE MECHANICAL DRAWINGS FOR LOCATIONS OF EXISTING CHILLERS, CONDENSING UNITS, ETC. ON ROOF.

GVA PROJECT No.
 2911
 CAD FILE
 E_2FL-EXIST
 LAST REVISION
 7-7-10
 PLOT DATE
 7-7-10
 PLOT SCALE
 1=1

GVA ENGINEERING, L.L.C.
 PROJECT No. 2911

T:\CADPROJ\2800\S\2911\E_2FL-EXIST.dwg, 7/6/2010 3:16:26 PM, GVT