


ELECTRICAL
SECOND FLOOR PLAN - RENOVATION

SCALE: 1/8"=1'-0"

- NOTES**
1. SEE PANELBOARD SCHEDULE AND SCHEMATIC FEEDER DIAGRAMS.
 2. UNLESS NOTED OTHERWISE, EXISTING ELECTRICAL EQUIPMENT IS DASHED.
 3. PROVIDE WIRING, RACEWAY SYSTEMS, ETC. TO RE-CIRCUIT EXISTING LIGHTING FIXTURES, SWITCHES, ETC. TO BE REUTILIZED. CONNECT TO PANEL L2A (NOT E2A).
 4. CIRCUITS L1A6,8,10,12 SHALL EACH BE LOADED @ 1500 WATTS. PROVIDE PROPER TRACK HARDWARE AND ACCESSORIES FOR LOADING AS DIRECTED FOR TWO CIRCUIT TRACK FOR RISEN LORD LIGHTING.



T:\CAD\PROJ\2900\S\2911\E_2FL-RENO.dwg: 7/7/2010 11:53:30 AM: GVT

QA PROJECT No	2911
QA FILE	E-2FL-RENO
LAST REVISION	7-7-10
PLT DATE	7-7-10
PLT SCALE	1=1